

Annexure C


PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.0494

Dated:29-08-2025

It is certified that an inspection team headed by Khiraj Kumar Kalita, Asst. Engineer from Goalpara PHED inspected the Sainik School , Mornoi, Goalpara on 17-06-2025 and on the basis of Water Test Report (Attached) bearing no 0493, 0495. Dated 19-06-2025 of Goalpara DLL (PHED Lab) certified that the Sainik School , Mornoi, Goalpara. has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 19-12-2025.

Signature with Seal: 
Asst. Executive Engineer (PHE)
Goalpara Sub-Divn., Goalpara

Name : Pranj Nath

Designation : Asst. Executive Engineer

Name & Address of the Office / Department :

PHE Goalpara Division

To
Sainik School Mornoi, Goalpara

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

DISTRICT LEVEL LABORATORY, GOALPARA

Address: Office of the Executive Engineer (PHE)


Goalpara Division, Goalpara

Email: dllphegoalpara@gmail.com



TC-13496

ULR No. : TC1349625L0000495F
Issue Date : 19-06-2025
Issued To : Sainik School, Goalpara (Tank)
Customer Reference No : 0495 (U1413063S30108548)
Sample Description : Sample Bottle Properly Sealed
Sample Location : Sainik School, Goalpara (Tank)
Address : Matia, Mornoi, Goalpara
Sample Type : Raw Water
Sample Quantity : 1 ltr
Sample collected on dated : 17-06-2025
Sample received on dated : 17-06-2025
Sample Collected by : Dimbeswar Das
Date of Analysis Started : 17-06-2025 : Date of Analysis is Complete :- 19-06-2025



Test Report

Sl. No.	Parameter	Protocol Used	Results	IS: 10500:2012 (Second Revision)		Unit
				Desirable limit	Max. Permissible limit (in absence better alternate source)	
1	pH	IS: 3025: (Part 11) : 2017	7.22	6.5 – 8.5	No relaxation	pH Units
2	Total Dissolved Solids	IS: 3025: (Part 16) : 2017	240	500	2000	mg/L
3	Turbidity	IS: 3025: (Part 10) : 2017	1.1	1	5	NTU
4	Iron	APHA 23 rd Edition-3500-Fe Method B (Phenanthroline Method): 2017	0.10	1	No relaxation	mg/L
5	Nitrate	APHA 23 rd Edition-4500 NO ₃ Method B (UV Screening Method): 2017	1.04	45	No relaxation	mg/L
6	Chloride	IS: 3025: (Part 32) : 2019	2.83	250	1000	mg/L
7	Total Hardness	IS: 3025: (Part 21) : 2019	182.98	200	600	mg/L
8	Total Alkalinity	IS: 3025: (Part 23) : 2019	56	200	600	mg/L
9	Calcium (as Ca)	IS:3025 : (Part 40) : 2019	21.42	75	200	mg/L
10	Magnesium	IS:3025 : (Part 46) : 2019	15.48	30	100	mg/L
11	Sulphate	APHA 23 rd Edition-4500- SO ₄ Method E (Turbidimetric Method) : 2017	5.61	200	400	mg/L
12	Arsenic	IS 3025: (Part 37) RA2019:1988	BDL	0.01	No relaxation	mg/L
13	Fluoride	APHA 4500- F (SPADNS Method)	0.22	1	1.5	mg/L
14	Colour	IS: 3025: (Part 4) : 2017	05	5	15	Hazen
15	Odour	IS: 3025: (Part 5) : 2018	Agreeable	Agreeable	Agreeable	
16	Taste	IS: 3025: (Part 8) : 2017	Agreeable	Agreeable	Agreeable	

Note

- The results given above are related to the sample as received and tested in this laboratory. Reliability of sample lies with the sensor.
- The test report cannot be regenerated/re-produced in whole or in part without written permission of Laboratory.
- The test report cannot be used for any publicity or any legal purpose.
- The test samples meant for chemical analysis will be disposed of after 15 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Sample analyzed by: Mukut Bharali

Approved by: Pranjal Ray

Verified by: Surabhi Rabha

Microbiologist
Microbiologist (PHE)
DLL, Goalpara

Quality Manager
Assistant Chemist (F.H.E.)
DLL, Goalpara
DLL, Goalpara

DISTRICT LEVEL LABORATORY, GOALPARA

Address: Office of the Executive Engineer (PHE)

Goalpara Division, Goalpara

Email: dllphegoalpara@gmail.com

Issue Date : 19-06-2025
 Issued To : Sainik School, Goalpara (Tank)
 Customer Reference No : 0495 (U1413063S30108548)
 Sample Description : Sample Bottle Properly Sealed
 Sample Location : Sainik School, Goalpara (Tank)
 Address : Matia, Mornoi, Goalpara
 Sample Type : Raw Water
 Sample Quantity : 1 ltr
 Sample collected on dated : 17-06-2025
 Sample received on dated : 17-06-2025
 Sample Collected by : Dimbeswar Das
 Date of Analysis Started : 17-06-2025 : Date of Analys is Complete :- 19-06-2025



Test Report

Sl. No.	Parameter	Protocol Used	Results	IS: 10500:2012 (Second Revision)		Unit
				Desirable limit	Max. Permissible limit (in absence better alternate source)	
1	Residual Chlorine	Iodometric Method I (APHAn4500- Cl B)	0.00	0.2	1	mg/L
2	Ecoli	MF-Technique	0.00	0.00	No relaxation	CFU/100ml

Note

- The results given above are related to the sample as received and tested in this laboratory. Reliability of sample lies with the sensor.
- The test report cannot be regenerated/re-produced in whole or in part without written permission of Laboratory.
- The test report cannot be used for any publicity or any legal purpose.
- The test samples meant for chemical analysis will be disposed of after 15 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Sample analyzed by: Mukut Bharali

Verified by: Surabhi Rabha

Microbiologist
 Microbiologist (PHE)
 DLL, Goalpara

Approved by: Pranjal Ray

Quality Manager
 Assistant Chemist (F.H.E.)
 DLL, Goalpara

DISTRICT LEVEL LABORATORY, GOALPARA

Address: Office of the Executive Engineer (PHE)

Goalpara Division, Goalpara

Email: dllphegoalpara@gmail.com



TC-13496

ULR No. : TC1349625L0000493F
Issue Date : 19-06-2025
Issued To : Sainik School, Goalpara(Lachit)
Customer Reference No : 0493 (U1413063S30108417)
Sample Description : Sample Bottle Properly Sealed
Sample Location : Sainik School, Goalpara(Lachit)
Address : Matia, Mornoi, Goalpara
Sample Type : Treated Water
Sample Quantity : 1 ltr
Sample collected on dated : 17-06-2025
Sample received on dated : 17-06-2025
Sample Collected by : Dimbeswar Das
Date of Analysis Started : 17-06-2025 : Date of Analysis is Complete :- 19-06-2025



Test Report

Sl. No.	Parameter	Protocol Used	Results	IS: 10500:2012 (Second Revision)		Unit
				Desirable limit	Max. Permissible limit (in absence better alternate source)	
1	pH	IS: 3025: (Part 11) : 2017	7.26	6.5 – 8.5	No relaxation	pH Units
2	Total Dissolved Solids	IS: 3025: (Part 16) : 2017	220	500	2000	mg/L
3	Turbidity	IS: 3025: (Part 10) : 2017	1.4	1	5	NTU
4	Iron	APHA 23 rd Edition-3500-Fe Method B (Phenanthroline Method): 2017	0.14	1	No relaxation	mg/L
5	Nitrate	APHA 23 rd Edition-4500 NO3 Method B (UV Screening Method): 2017	1.02	45	No relaxation	mg/L
6	Chloride	IS: 3025: (Part 32) : 2019	7.09	250	1000	mg/L
7	Total Hardness	IS: 3025: (Part 21) : 2019	128.50	200	600	mg/L
8	Total Alkalinity	IS: 3025: (Part 23) : 2019	58	200	600	mg/L
9	Calcium (as Ca)	IS:3025 : (Part 40) : 2019	21.42	75	200	mg/L
10	Magnesium	IS:3025 : (Part 46) : 2019	11.68	30	100	mg/L
11	Sulphate	APHA 23 rd Edition-4500- SO4 Method E (Turbidimetric Method) : 2017	5.09	200	400	mg/L
12	Arsenic	IS 3025: (Part 37) RA2019:1988	BDL	0.01	No relaxation	mg/L
13	Fluoride	APHA 4500- F (SPADNS Method)	0.36	1	1.5	mg/L
14	Colour	IS: 3025: (Part 4) : 2017	05	5	15	Hazen
15	Odour	IS: 3025: (Part 5) : 2018	Agreeable	Agreeable	Agreeable	
16	Taste	IS: 3025: (Part 8) : 2017	Agreeable	Agreeable	Agreeable	

Note

- 1 The results given above are related to the sample as received and tested in this laboratory. Reliability of sample lies with the sensor.
- 2 The test report cannot be regenerated/re-produced in whole or in part without written permission of Laboratory.
- 3 The test report cannot be used for any publicity or any legal purpose.
- 4 The test samples meant for chemical analysis will be disposed of after 15 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Sample analyzed by: Mukut Bharali

Approved by: Pranjal Ray

Verified by: Surabhi Rabha

Microbiologist
DLL Goalpara
DLL, Goalpara

Assistant Chemist (F.H.E.)
DLL Goalpara

DISTRICT LEVEL LABORATORY, GOALPARA

Address: Office of the Executive Engineer (PHE)

Goalpara Division, Goalpara

Email: dllphegoalpara@gmail.com

Issue Date : 19-06-2025
Issued To : Sainik School, Goalpara(Lachit)
Customer Reference No : 0493 (U1413063S30108417)
Sample Description : Sample Bottle Properly Sealed
Sample Location : Sainik School, Goalpara(Lachit)
Address : Matia, Mornoi, Goalpara
Sample Type : Treated Water
Sample Quantity : 1 ltr
Sample collected on dated : 17-06-2025
Sample received on dated : 17-06-2025
Sample Collected by : Dimbeswar Das
Date of Analysis Started : 17-06-2025 : Date of Analysis is Complete :- 19-06-2025



Test Report

Sl. No.	Parameter	Protocol Used	Results	IS: 10500:2012 (Second Revision)		Unit
				Desirable limit	Max. Permissible limit (in absence better alternate source)	
1	Residual Chlorine	Iodometric Method I (APHA4500- Cl B)	0.00	0.2	1	mg/L
2	Ecoli	MF-Technique	0.00	0.00	No relaxation	CFU/100ml

Note

- 1 The results given above are related to the sample as received and tested in this laboratory. Reliability of sample lies with the sensor.
- 2 The test report cannot be regenerated/re-produced in whole or in part without written permission of Laboratory.
- 3 The test report cannot be used for any publicity or any legal purpose.
- 4 The test samples meant for chemical analysis will be disposed of after 15 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Sample analyzed by: Mukut Bharali

Approved by: Pranjal Ray

Verified by: Surabhi Rabha

Microbiologist
Microbiologist (PHE)
DLL Goalpara
DLL, Goalpara

Quality Manager
Assistant Chemist (F.H.E.)
DLL, Goalpara
DLL Goalpara